



City of Fond du Lac  
First on the Lake

Website: [www.fdl.wi.gov](http://www.fdl.wi.gov)

City-County Government Center  
160 S. Macy Street~P.O. Box 150~Fond du Lac, WI 54936-0150

ADDENDUM #1  
MORRIS STORAGE BUILDING  
CITY OF FOND DU LAC, WI  
FILE NO. 2015-070

June 23, 2015

Notice is hereby given that the following change had been made on the above titled project:

1. Material Substitution – Expanded Polystyrene (EPS) foam board insulation may be used in place of extruded polystyrene (Styrofoam - XPS) insulation in Option #2 of specifications.

Please acknowledge receipt of Addendum #1 as a notation on the Proposal document when completing bid.

Sincerely,

Kathryn Scharf  
Water Operations Manager